

D-LABORATOR

BULETIN ANALIZA NR. 36./DATA. 28.10.2010

APE DEVERSATE IN IER

Indicator	UM	Valori max.admise	Valori obtinute	Observatii
pH	-	6,5-8,5	8,0	
Materii in suspensie	mg/l	60	10,5	
CBO ₅	mg/l	25	2,5	
CCO-Cr	mg/l	125	8,9	
Reziduu fiz	mg/l	2000	120	
Azot amoniacal	mg/l	3	0,1	
Fe total	mg/l	5	0,1	

Sef sectie ing. Dihel Adela

