


CET ARAD-LABORATOR

BULETIN ANALIZA NR. 28 / DATA 02.11.2017.

APE DEVERSATE IN IER

Indicator	UM	Valori max.admise	Valori obtinute	Observatii
pH	-	6,5-8,5	8,3	
Materii in suspensie	mg/l	60	21,2	
CBO ₅	mg/l	25	16	
CCO-Cr	mg/l	125	53	
Reziduu fiz	mg/l	2000	1260	
Azot amoniacal	mg/l	3	0,1	
Fe total	mg/l	5	0,2	

Sef sectie ing. Dihel Adela



CET ARAD-LABORATOR

BULETIN ANALIZA NR. 29 / DATA 07.11.2017.

APE DEVERSATE IN IER

Indicator	UM	Valori max.admise	Valori obtinute	Observatii
pH	-	6,5-8,5	8,2	
Materii in suspensie	mg/l	60	16	
CBO ₅	mg/l	25	8,1	
CCO-Cr	mg/l	125	24	
Reziduu fiz	mg/l	2000	1350	
Azot amoniacal	mg/l	3	0,1	
Fe total	mg/l	5	0,2	

Sef sectie ing. Dihel Adela

