

BULETIN ANALIZA NR. 21. DATA: 15.07. 2017

APE DEVERSATE IN IER

Indicator	UM	Valori max. admise	Valori obtinute	Observatii
pH	-	6,5-8,5	8,2	
Materii in suspensie	mg/l	60	21,5	
CBO ₅	mg/l	25	7,2	
CCO-Cr	mg/l	125	23	
Reziduu fiz	mg/l	2000	1520	
Azot amoniacal	mg/l	3	0,1	
Fe total	mg/l	5	0,1	

Sef sectie ing. Dihel Adela

