

CET ARAD-LABORATOR

BULETIN ANALIZA NR. 20.../DATA... 12.06.2012

APE DEVERSATE IN IER

Indicator	UM	Valori max.admise	Valori obtinute	Observatii
pH	-	6,5-8,5	8,2	
Materii in suspensie	mg/l	60	20,1	
CBO <sub>5</sub>	mg/l	25	2,5	
CCO-Cr	mg/l	125	24	
Reziduu fiz	mg/l	2000	1500	
Azot amoniacal	mg/l	3	0,1	
Fe total	mg/l	5	0,1	

Sef sectie ing. Dihel Adela

