

BULETIN ANALIZA NR. 30 / DATA 15.11.2019

APE DEVERSATE IN IER

Indicator	UM	Valori max.admise	Valori obtinute	Observatii
pH	-	6,5-8,5	8,2	
Materii in suspensie	mg/l	60	16	
CBO ₅	mg/l	25	5,3	
CCO-Cr	mg/l	125	14,6	
Reziduu fiz	mg/l	2000	1214	
Azot amoniacal	mg/l	3	0,2	
Fe total	mg/l	5	0,9	

Sef sectie ing. Dihel Adela

BULETIN ANALIZA NR. 31 / DATA 23 NOV 2019

APE DEVERSATE IN IER

Indicator	UM	Valori max.admise	Valori obtinute	Observatii
pH	-	6,5-8,5	8,2	
Materii in suspensie	mg/l	60	17	
CBO ₅	mg/l	25	7,2	
CCO-Cr	mg/l	125	26,4	
Reziduu fiz	mg/l	2000	1250	
Azot amoniacal	mg/l	3	0,1	
Fe total	mg/l	5	0,2	

Sef sectie ing. Dihel Adela

BULETIN ANALIZA NR. 32 / DATA 28 NOV 2019

APE DEVERSATE IN IER

Indicator	UM	Valori max.admise	Valori obtinute	Observatii
pH	-	6,5-8,5	8,2	
Materii in suspensie	mg/l	60	15	
CBO ₅	mg/l	25	7,9	
CCO-Cr	mg/l	125	26,4	
Reziduu fiz	mg/l	2000	1110	
Azot amoniacal	mg/l	3	0,1	
Fe total	mg/l	5	0,1	

Sef sectie ing. Dihel Adela